

**NORTON HILL PAVILION LEGIONELLA CHECKS  
 QUARTERLY CLEANING AND DESCALING**

DATE	LOCATION	COMMENTS	SIGNED
04/09/2019	Kitchen		CCS
04/09/2019	Home changing room		CCS
04/09/2019	Away changing room		CCS
04/09/2019	Referees room		CCS

**WATER TEMPERATURE RECORD FORM**

Norton Hill Pavilion - MONTHLY

COLD WATER TEMPERATURE RECORDED AFTER RUNNING OUTLET FOR TWO MINUTES

HOT WATER TEMPERATURE RECORDED AFTER RUNNING OUTLET FOR ONE MINUTE

Date	Location	Before the thermostatic mixing valve	Hot Water at the outlet	Cold Water	Comments	Signature
		Should exceed 50	Should be between 39-45	Should be below 20		
03/09/2019	Kitchen	51.1	40.6	18.8		JC
03/09/2019	Home changing room	51.1	40.6	18.8		JC
03/09/2019	Away changing room	51.1	40.6	18.8		JC
03/09/2019	Referee's changing room	51.1	40.6	18.8		JC